

Recent Advances in Computational Methods for the Power Flow Equations

Dhagash Mehta¹, Daniel K. Molzahn², and Konstantin Turitsyn³

Abstract—The power flow equations are at the core of most of the computations for designing and operating electric grids. This system of multivariate nonlinear equations relate the power injections and voltages in an electric power system. A plethora of methods have been devised to solve these equations, from Newton-based methods to homotopy continuation and other optimization-based methods. Although many of these methods often efficiently find a high-voltage, stable solution, challenges remain for finding low-voltage solutions, which play significant roles in certain stability-related computations. While we do not claim to have exhausted the existing literature on all related methods, this tutorial paper introduces some of the recent advances in power flow solution methods to the wider power systems community as well as bringing attention from the computational mathematics and optimization communities to power systems problems. After briefly reviewing some of the traditional computational methods used to solve the power flow equations, we focus on three emerging methods: the numerical polynomial homotopy continuation method, Gröbner basis techniques, and moment/sum-of-squares relaxations using semidefinite programming. In passing, we also emphasize the importance of an upper bound on the number of solutions of the power flow equations and review the current status of research in this direction.

I. INTRODUCTION

The power flow equations model the steady-state relationship between the complex voltage phasors and the power injections in an electric power system. Power systems typically operate at a “high-voltage” solution to the power flow equations that corresponds to a stable equilibrium of the differential-algebraic equations modeling power system dynamics. Section II of this paper gives an overview of the power flow equations.

Calculating a high-voltage power flow solution has been the subject of research efforts for over fifty years. There exist a variety of mature iterative methods, often based on Newton’s method and related variants [1], [2] or the Gauss-Seidel method [3], that are capable of solving many practical large-scale power flow problems. Convergence of these iterative methods depends on the selection of an appropriate initialization. Reasonable initializations, such as the solution to a related problem or a “flat start” consisting

of a $1\angle 0^\circ$ voltage profile, often result in convergence to the high-voltage power flow solution. However, determining an appropriate initialization is challenging when parameters move outside typical operating ranges as may occur with high penetrations of renewable generation and during contingencies. Illustrating this initialization challenge, [4] and [5] demonstrate that the basins of attraction for Newton-based power flow solution methods are fractal in nature.

This challenge has motivated a variety of approaches for improving the robustness of Newton-based methods with respect to the choice of initialization. For instance, [6] calculates an “optimal multiplier” at each iteration of the Newton algorithm that prevents divergence. Other approaches consider alternate formulations of the power flow equations, such as [7] which applies a Newton-based iteration to a formulation that includes both voltages and currents.

There has been significant recent interest in alternatives to Newton-based methods. For instance, the Holomorphic Embedding Load Flow method [8], which uses analytic continuation theory from complex analysis, is claimed to be capable of reliably finding a stable solution for any feasible set of power flow equations. Approaches based on monotone operator and convex optimization theory [9], [10] identify regions with at most one power flow solution. After identifying such a region, any solution contained within can be quickly calculated. Convex relaxation techniques can also calculate power flow solutions [11] and certify infeasibility [12]–[14]. Additionally, progress has been made using “decoupling” approximations that facilitate separate analysis of the active and reactive power flow equations [15]–[17].

Many existing approaches focus primarily on calculation of the high-voltage power flow solution. However, other power flow solutions generally exist, often at lower voltages [18]–[23]. These solutions are important for many types of power system stability assessments [24]–[28]. Additionally, studying non-convexities in the power flow feasible space related to multiple solutions can help explain the behavior of convex relaxations of power system optimization problems [29], [30]. There may also exist multiple stable power flow solutions [31], particularly in the presence of power flow reversal on distribution systems [32], [33].

Attempts to calculate multiple power flow solutions include the use of a Newton-based algorithm with a range of carefully chosen initializations [34], [35]. Using semidefinite relaxations of the power flow equations with objectives that are functions of squared voltage magnitudes, [36] also identifies multiple power flow solutions. By considering various regions characterized by a monotonicity property,

¹University of Notre Dame, Dept. of Applied and Computational Mathematics and Statistics; University of Adelaide, School of Physical Sciences, Dept. of Physics, Centre for the Subatomic Structure of Matter. Support from NSF-ECCS award ID 1509036 and an Australian Research Council DECRA fellowship no. DE140100867. dmehta@nd.edu, Preprint No: ADP-15-35/T937

²Argonne National Laboratory, Energy Systems Division. dmolzahn@anl.gov

³Department of Mechanical Engineering, Massachusetts Institute of Technology. turitsyn@mit.edu

multiple power flow solutions can be computed using the theory developed in [10]. Other approaches include the use of an auxiliary gradient system [37] and a holomorphic embedding method [38]. However, there are no known systematic methods based on these approaches that are guaranteed to yield all power flow solutions.

A numerical continuation approach that claims to find all power flow solutions was presented in [39]. Since it scales with the number of *actual* rather than *potential* power flow solutions, this approach is computationally tractable for realistic power systems. However, the robustness proof indicating that this approach finds all solutions to all power flow problems is flawed [40], and [41] presents a counterexample. This counterexample also invalidates the robustness of the related approach in [42] for calculating all power flow solutions that have a certain stability property. Recent work [43] presents a related method that improves the robustness of [39].

Although not yet scalable to large systems, there are approaches which are guaranteed to find all power flow solutions. As described in Section III, the most computationally tractable of these methods are based on numerical polynomial homotopy continuation (NPHC). Existing techniques are tractable for systems with up to 14 buses [44]–[46] (and the equivalent of 18 buses for the related Kuramoto model [47]). The NPHC methods use continuation to trace all complex solutions from a selected “simple” polynomial system for which all solutions can be easily calculated to the solutions of the specified target system. In this context, the power flow equations are transformed by splitting real and imaginary parts of the voltage phasors to obtain polynomials in real variables. Thus, only the real solutions to these polynomial equations are physically meaningful. Nevertheless, ensuring recovery of all real solutions requires a number of continuation traces that depends on an upper bound for the number of complex solutions. Apart from being theoretically interesting, tighter upper bounds on the number of power flow solutions would thus improve the computational tractability of NPHC methods. Existing bounds [20], [21], [23], [48] are based on calculations of the number of complex solutions for *complete* (i.e., fully connected) networks. Recent work [49] uses NPHC to find all complex solutions for a variety of small test cases in order to inform conjectured upper bounds that are based on the network topology. NPHC is also applied to a variety of small test cases in [48]. Other recent work [50] constructs network topology dependent and tighter¹ upper bounds using the adjacency polytope for the power flow equations.

Other methods guaranteed to find all solutions to systems of polynomials (which may therefore be applied to the power flow equations) are the eigenvalue technique in [51], interval analysis [52], Gröbner bases (Section IV), and the “moment/sum-of-squares” relaxations in [53] and Section V.

Section IV overviews the Gröbner basis techniques. In addition to solving the power flow equations, these techniques

are presented in the contexts of equivalencing methods, bifurcation analyses, and dynamic power system models.

Section V describes recent progress in moment/sum-of-squares relaxations of the power flow equations. While these relaxations are applicable to many power systems computations, this work is presented in the context of the *optimal power flow* (OPF) problem. Specifically, the OPF problem seeks the voltages which result in power injections that minimize operational cost while satisfying both the power flow equations and engineering limits. The moment/sum-of-squares relaxations lower bound the optimal objective value and, for many OPF problems, give the global solution.

II. OVERVIEW OF THE POWER FLOW EQUATIONS

Consider an n -bus electric power system where $\mathcal{N} = \{1, \dots, n\}$ is the set of buses and \mathcal{G} is the set of generator buses.² The network admittance matrix, which contains the electrical parameters of the network as well as the topology information, is denoted $\mathbf{Y} = \mathbf{G} + \mathbf{j}\mathbf{B}$, where $\mathbf{j} = \sqrt{-1}$. (See, e.g., [54] for details on the construction of the admittance matrix.)

Each bus has two associated complex values: the voltage phasors and the power injections. We will use both complex voltage phasor representation $V \in \mathbb{C}^n$ and rectangular voltage coordinates $V_d + \mathbf{j}V_q$, $V_d, V_q \in \mathbb{R}^n$. Each bus $i \in \mathcal{N}$ has active and reactive power injections $P_i + \mathbf{j}Q_i$, $P, Q \in \mathbb{R}^n$.

In terms of complex voltages, the power flow equations are polynomials in V and \bar{V} :

$$P_i = \text{Re} \left(V_i \sum_{k=1}^n \bar{Y}_{ik} \bar{V}_k \right) \quad (1a)$$

$$Q_i = \text{Im} \left(V_i \sum_{k=1}^n \bar{Y}_{ik} \bar{V}_k \right) \quad (1b)$$

where $\bar{(\cdot)}$ indicates the complex conjugate and $\text{Re}(\cdot)$ and $\text{Im}(\cdot)$ return the real and imaginary parts, respectively, of a complex argument. Squared voltage magnitudes are

$$|V_i|^2 = V_i \bar{V}_i. \quad (1c)$$

Splitting real and imaginary parts of (1) and using rectangular voltage coordinates yields quadratic polynomials in real variables V_d and V_q . The active and reactive power injections at bus i are

$$P_i = V_{di} \sum_{k=1}^n (\mathbf{G}_{ik} V_{dk} - \mathbf{B}_{ik} V_{qk}) + V_{qi} \sum_{k=1}^n (\mathbf{B}_{ik} V_{dk} + \mathbf{G}_{ik} V_{qk}) + P_{Di} \quad (2a)$$

$$Q_i = V_{di} \sum_{k=1}^n (-\mathbf{B}_{ik} V_{dk} - \mathbf{G}_{ik} V_{qk}) + V_{qi} \sum_{k=1}^n (\mathbf{G}_{ik} V_{dk} - \mathbf{B}_{ik} V_{qk}) + Q_{Di}. \quad (2b)$$

¹In fact, these new bounds are the tightest possible bounds for the generic values of the parameters.

²A “bus” in power system terminology represents a node in the graph corresponding to the power system network. A “line” corresponds to an edge of this graph.

Squared voltage magnitudes are

$$|V_i|^2 = V_{di}^2 + V_{qi}^2. \quad (2c)$$

To represent typical equipment behavior, each bus is traditionally classified as PQ, PV, or slack. PQ buses, which typically correspond to loads, treat P_i and Q_i as specified quantities and enforce the active and reactive power equations. PV buses, which typically correspond to generators, enforce the active power and squared voltage magnitude equations with specified P_i and $|V_i|^2$. The associated reactive power Q_i may be computed as an “output quantity” via the reactive power equation.³ Finally, a single slack bus is selected with specified V_i (typically chosen such that the reference angle is 0° ; i.e., $\text{Im}(V_i) = 0$). The active power P_i and reactive power Q_i at the slack bus are determined from the active and reactive power equations, respectively; network-wide conservation of complex power is thereby satisfied. Solving the power flow equations means determining voltage phasors such that the enforced equations are satisfied at each bus.

III. THE NUMERICAL POLYNOMIAL HOMOTOPY CONTINUATION METHOD

The Numerical Polynomial Homotopy Continuation (NPHC) method [55]–[57] has recently gained attention as it successfully found all the solutions of the power flow equations (2) for the IEEE test systems with up to 14 buses [44]–[46]. The method has also been applied [47] to find all equilibria of the Kuramoto model [58], a prototypical model for the power flow equations [59], for up to an 18-bus case with different network topologies. This section provides an overview of the NPHC method and discusses recent work in determining upper bounds on the number of isolated complex solutions for the power flow equations.

A. Overview of the NPHC Method

The basic ingredient of the NPHC method, called homotopy continuation, has been used by mathematicians for quite some time [60]. To solve a system of nonlinear equations, one first constructs a “simple” system for which all solutions can be easily identified. The solutions of the simple system are then continuously deformed to obtain solutions of the original “target” system. However, in traditional continuation methods for general nonlinear systems, the solution-paths may cross one another, bifurcate, or turn back towards the simple system. In practice, one or more of these behaviors may be observed for general nonlinear systems. Thus, these methods generally do not guarantee finding all solutions.

For the specific case of systems of *polynomial* equations, however, the situation is different due to the maturity of algebraic geometry theory. For polynomial systems, one can construct a specific type of homotopy method, NPHC, between the simple system and the target system such that all the solution-paths are well-behaved. The NPHC method thus guarantees finding all isolated complex solutions of the target system of polynomial equations.

We now describe the specific strategy for the NPHC method. Denote the transpose as $(\cdot)^\top$. Define the target system to be solved as $f(x) = 0$, where $f(x)$ is a vector of n polynomial equations $f(x) := [f_1(x) \ \dots \ f_n(x)]^\top$ and x is a vector of n variables $x := [x_1 \ \dots \ x_n]^\top$. To utilize theory from algebraic geometry, we consider $x \in \mathbb{C}^n$. If only real solutions are physically relevant, as is the case for the power flow equations (2), we disregard all the non-real solutions upon completion of the method.

The NPHC method starts by calculating an upper bound on the number of isolated complex solutions of $f(x) = 0$. There exist various off-the-shelf upper bounds arising from the computational algebraic geometry literature. The classical Bézout bound (CBB) states that the number of complex isolated solutions for a system of polynomial equations is at most the product of degree of each of the polynomials: $\prod_{i=1}^n d_i$, where d_i is the degree of $f_i(x)$.⁴ A discussion on tighter upper bounds for the power flow equations is presented later in this section.

Using an upper bound on the number of complex solutions, one constructs a “simple” system in the same variables, $g(x) = 0$, such that 1) the simple system has the same number of isolated complex solutions as the upper bound, and 2) obtaining all the solutions of $g(x) = 0$ is straightforward. Using the CBB, such a system is $g(x) := [a_1 x_1^{d_1} - b_1 \ \dots \ a_n x_n^{d_n} - b_n]^\top$, where $a_i, b_i \neq 0$ are generic complex numbers. The system $g(x) = 0$ has $\prod_{i=1}^n d_i$ isolated solutions: $x_i = \sqrt[d_i]{\frac{b_i}{a_i}}$.

The NPHC method then constructs a homotopy between $f(x)$ and $g(x)$:

$$H(x; t) := (1 - t) f(x) + \eta t g(x) = 0, \quad (3)$$

where $t \in [0, 1]$. At $t = 1$, we have $g(x) = 0$ and know all the solutions by construction. At $t = 0$, we recover the original system $f(x) = 0$. Hence, for each of the solutions of $g(x) = 0$, a path from $t = 1$ to $t = 0$ is tracked using an efficient path-tracker [57], such as a predictor-corrector method. Since the upper bound on the number of solutions of $f(x) = 0$ may not be exact, some of the solution-paths may diverge to infinity along the way. It has been shown that exactly as many paths as the number of isolated complex solutions, counting multiplicity, of $f(x) = 0$ reach $t = 0$ so long as η in (3) is chosen generically from \mathbb{C} [57]. In other words, for $t \in (0, 1]$ with a generic complex η , it is proven that no path will cross other paths, turn back, or bifurcate. (Note that more than one path may sometimes reach the same solution at $t = 0$ if the system has multiple solutions.) Hence, in the end, the NPHC method is guaranteed to yield *all* isolated complex solutions of a system of polynomial equations. The method is *embarrassingly parallelizable* since each path can be tracked independently, and is thus suitable for high-performance supercomputing clusters.

³Note that this paper does not consider reactive-power-limited generators.

⁴The power flow equations are degree-two polynomials.

B. Upper Bounds on the Number of Power Flow Solutions

The efficiency of the NPHC method strongly depends on the quality of the upper bounds on the isolated complex solutions of the power flow equations, as this is the number of solution-paths one has to track. Another determinant of the efficiency of the method is the computational effort required to compute the upper bound and solve the corresponding start system $g(x) = 0$. The CBB is trivial to compute for any given system, and solving the corresponding start system is also straightforward. However, in practice, the number of complex solutions is usually much lower than the CBB due to the sparsity of the system. Hence, computational effort is wasted in tracking paths that eventually diverge.

The computational tractability of the NPHC method can be improved by using tighter bound on the number of complex solutions to the power flow equations. One approach for computing high-quality upper bounds is by exploiting the sparsity structure inherent to the power flow equations, which is encoded inside the network topology of the power system.

After fixing the slack bus voltage, there are $2(n-1)$ power flow equations for an n -bus system, each of which is a quadratic polynomial. Thus, the CBB is $2^{2(n-1)}$. A tighter upper bound, $\binom{2n-2}{n-1}$, on the number of complex solutions was first proposed in [20] for lossless systems without PQ buses, extended to (potentially lossy) systems without PV buses in [21], and finally to general power systems in [23]. (See [48] for an alternative proof of this bound.) In [44], it was pointed out that a generic upper bound, called the BKK bound (named after its inventors Bernstein-Khovanskii-Kushnirenko [61]–[63]), was significantly smaller than the CBB for the IEEE test case with up to 14 buses. However, no theoretical justification for this observation is yet known.

These bounds do not consider the sparsity structure of the power flow polynomials. There is some existing work on bounds that are functions of the network topology. The bound in [64] applies to power systems whose network graphs are composed of subgraphs having exactly one shared bus. The number of isolated complex solutions for such systems is equal to the product of number of solutions for the individual subgraphs. Using numerical experiments conducted with the NPHC method, recent results in [49] conjecture an upper bound for systems whose network graphs are composed of *maximal cliques* (i.e., maximally sized, completely connected subgraphs) which share exactly two buses along with some other technical conditions. The work in [50] reviews existing upper bounds and constructs new upper bounds based on the adjacency polytope of the power flow equations. For a given network topology, [50] shows that some of the bounds on the number of complex solutions are attainable for some choice of electrical parameters.

IV. THE GRÖBNER BASIS TECHNIQUES

As discussed in the previous sections, many important power systems problems are naturally formulated in terms of systems of polynomial equations. The classical and perhaps most important is the system of power flow equations. Other examples include but are not limited to loadability limits,

small-signal stability and others. These systems of equations define an algebraic set characterizing the relation between system variables and parameters. Although these relations are usually defined in high-dimensional spaces, the important engineering questions usually involve only a few variables and parameters. For example, classical loadability and path rating analysis addresses the questions of system response to variation of specific load consumption levels.

Gröbner basis techniques provide a formal way to construct all the solutions of polynomial systems equations. Apart from offering an alternative to other techniques described in this tutorial, they also allow elimination of variables from these systems at the expense of raising the total degree of equations. In the following we provide an informal introduction to the algebraic geometry concepts necessary to understand the ideas of Gröbner bases. The reader is referred to [65] for an accessible but formal and thorough introduction to the subject.

From algebraic perspective, any polynomial equations in x_1, \dots, x_n variables with real coefficients is an element of the so-called polynomial ring $\mathbb{R}[x_1, \dots, x_n]$ or $\mathbb{R}[\mathbf{x}]$ – the set of polynomials in x_1, \dots, x_n with real coefficients with the naturally defined addition and multiplication operations. Like elements of other rings, for example integer numbers, the polynomials can be sometimes factorized into products of lower-order polynomials, for example $x_1^2 - x_2^2 = (x_1 - x_2)(x_1 + x_2)$, which allows the definition of a long division operation on the polynomial ring. Whenever the degree of polynomial $Q \in \mathbb{R}[\mathbf{x}]$ is less than the degree of polynomial $P \in \mathbb{R}[\mathbf{x}]$, one can always represent $P = UQ + R$, where U is the quotient and R the remainder polynomials, each with lower order in comparison to Q . As there is no natural ordering on multivariable polynomials, typically a lexicographic ordering is used, where the monomials are ordered lexicographically, so $1 \prec x_1 \prec x_1^2 \prec \dots \prec x_2 \prec x_2x_1 \prec x_2x_1^2 \prec \dots \prec x_2^2$ etc, and polynomials are ordered with respect to the highest monomial order, so, for example $x_1^2 + x_2^2 \succ 2x_1x_2$ because $x_1^2 \succ 2x_1x_2$. Given a polynomial ordering, the long division is uniquely defined. For example, dividing $P = x_1^2 + x_2^2$ by $Q = x_1 + x_2$ one gets $x_1^2 + x_2^2 = (x_2 - x_1)(x_1 + x_2) + 2x_1^2$.

An *ideal* $\langle P_1, \dots, P_m \rangle$ generated by polynomials $P_1(\mathbf{x}), \dots, P_m(\mathbf{x}) \in \mathbb{R}[\mathbf{x}]$ is a set of polynomials that can be represented as linear combination of P_1, \dots, P_m , i.e. $f = g_1P_1 + \dots + g_mP_m$, where every coefficient $g_k \in \mathbb{R}[\mathbf{x}]$ is itself a polynomial in the same variable set. Any point \mathbf{y} that solves the system of equations $P_1(\mathbf{y}) = 0, \dots, P_m(\mathbf{y}) = 0$ is also a root of every polynomial P in the ideal $\langle P_1, \dots, P_m \rangle$. An ideal defines a set of equations that can be constructed from the original equations $P_k(x) = 0$ via algebraic addition and multiplication operations. Any ideal can be generated by various different base polynomials. For a trivial example, consider replacing the first equation $P_1(\mathbf{x}) = 0$ with $P_1(\mathbf{x}) + P_2(\mathbf{x}) = 0$. Obviously the new set of polynomials will define exactly the same ideal and characterize exactly the same algebraic set of solutions.

The Gröbner basis is a special representation of an ideal

that possesses a number of properties making it particularly suitable for solving elimination problems and also for constructing complete sets of solutions. For the lexicographic ordering of monomials defined above, the Gröbner basis provides a “triangular” representation of the ideal $\langle Q_1, \dots, Q_m \rangle$ with the following properties: $Q_1 = Q_1(x_n)$, $Q_2 = Q_2(x_{n-1}, x_n)$, and so on with $Q_n = Q_n(x_1, \dots, x_n)$ where we assumed for simplicity that $m = n$. Such a representation of the original system of equations provides a straightforward way of finding all the solutions. First, the univariate equation $Q_1(x_n) = 0$ can be solved to find all the values of x_n . This can be accomplished, for example, by constructing the companion matrix and finding its eigenvalues, or using the Newton method followed by factorization of the obtained solutions.

On the second step, the solutions of the first equation can be substituted into the equation $Q_2(x_{n-1}, x_n) = 0$ to find all the values of x_{n-1} . The obvious advantage of this approach is the transformation of the original multivariate problem to a sequence of univariate polynomial problems for which generally more straightforward methods exist both for identification of the solutions and for providing guarantees that no solution exist in specific regions. Certainly, the degree of the univariate polynomials can become very large for Gröbner bases constructed from large systems of equations. For systems of quadratic equations common to power systems, the degrees of the polynomials are bounded by 2^{2^n+1} where n is the total number of variables.

In many practical problems the goal is to characterize the dependence of one or many variables on external parameters. Algebraically, both the unknown variables x_1, \dots, x_m and external parameters p_1, \dots, p_k can be combined in a single variable set x_1, \dots, x_n with $n = m + k$ and $x_{m+i} = p_i$ for $i = 1, \dots, k$. In this case, the Gröbner basis takes the form $Q_1 = Q_1(x_m, x_{m+1}, \dots, x_n)$, $Q_2 = Q_2(x_{m-1}, \dots, x_n)$, and, finally $Q_m = Q_m(x_1, \dots, x_n)$. The first equations represents the implicit dependence of the unknown variable x_m on external parameters p_1, \dots, p_k represented by x_{m+1}, \dots, x_n .

The Gröbner basis can be constructed using the classical Buchberger’s algorithm which generalizes the classical Euclidean algorithm for finding the greatest common divisor of two integers to polynomial rings. In essence, the Buchberger algorithm implements the nonlinear version of the Gaussian elimination procedure and establishes the analogue of LU decomposition for nonlinear systems of equations. This algorithm is implemented in most general purpose computer algebra systems like Maple, Mathematica, Sagemath as well as specialized algebraic geometry systems like MAGMA and Singular. The algebraic nature of the algorithm requires exact arithmetic and definition of the problem on the polynomial ring $\mathbb{Q}[x]$ over field of rational rather than real numbers. This constraint reduces the computational efficiency of the algorithm and limits its applicability to large systems, although at the same time it eliminates the numerical error that can be accumulated in floating point manipulations. Existing implementations of Gröbner basis construction algorithms

do not exploit any structural properties of the underlying network graphs. However, recent generalization of the classical algorithm suggest that the complexity of the algorithm and degree of the resulting polynomials may be substantially lower than classical upper bounds for graphs with low treewidth typical for power systems [66]. So applications of Gröbner basis approach to large-scale power systems are not out of the question and may become realistic in the future with the maturation of algorithms exploiting the low treewidth of the underlying system graphs.

Below we discuss several potential applications of Gröbner basis techniques to power system analysis problems, illustrating the application of Gröbner basis techniques on the simple example of a two-bus power system.

The first application we discuss is equivalencing and model reduction. A power grid network has a hierarchical structure with high-voltage power line layers feeding the power to lower-voltage layers. Typically, the low-voltage distribution grid models representing the power consumers are aggregated into simple equivalents typically represented either with constant power PQ -buses or slightly more sophisticated ZIP models. The equivalencing of distribution grids happens in an ad-hoc non-systematic manner. Gröbner bases provide a tool for constructing the equivalent models in a systematic way. For a trivial example, consider a classical two-bus system where a bus 1 with voltage V is connected to a PQ load bus via a line of impedance $r + jx$. The effective load model as seen by the transmission grid represented by bus 1 is different from the constant specified PQ load due to losses in the line. The implicit model can be recovered by constructing the Gröbner basis for the following system of power flow equations:

$$P = Vi_d \quad (4)$$

$$Q = -Vi_q \quad (5)$$

$$V_d = V - ri_d + xi_q \quad (6)$$

$$V_q = -ri_q - xi_d \quad (7)$$

$$P_L = V_d i_d - V_q i_q \quad (8)$$

$$Q_L = -V_d i_q - V_q i_d. \quad (9)$$

In this system $V_d + jV_q$ represents voltage phasor at bus 2 and $i_d + ji_q$ represents the current phasor. The power levels P, Q represent the overall power consumption at bus 1, while P_L, Q_L correspond to consumption at load bus 2. The levels of r, x are set to $r = x = 1/4$ per unit (p.u.) for the sake of simplicity in this illustration, whereas the values of V, P_L , and Q_L are assumed to be independent parameters. Using the lexicographic ordering $i_d \prec i_q \prec V_d \prec V_q \prec Q \prec P \prec V \prec P_L \prec Q_L$, one can construct the Gröbner basis for this system and obtain the following first two generating equations:

$$2P^2 - 2AP + B = 0 \quad (10)$$

$$P - P_L - Q + Q_L = 0, \quad (11)$$

where $A = P_L - Q_L + 2V^2$ and $B = P_L^2 - 2P_L Q_L + Q_L^2 + 4P_L V^2$. These relations define an implicit model of




Fig. 1. Dependence of the total power consumption P on voltage at bus 1 for $P_L = 0.25 p.u.$, $Q_L = 0.25 p.u.$ (blue), $P_L = 0.25 p.u.$, $Q_L = 0.0 p.u.$ (orange), $P_L = 0.25 p.u.$, $Q_L = -0.25 p.u.$ (green).

the aggregate load, representing the dependence of the power consumption levels P and Q on terminal voltage V . Note that typically the value of V is affected by the flows in the transmission grid, while external parameters P_L and Q_L depend on the load consumption levels. This model can either be used directly or approximated by more common polynomial models of the loads. The resulting dependence is illustrated in Fig. 1. Note that the solution does not exist for low-voltage levels, which corresponds to phenomena referred to as voltage collapse in power system literature. Also, there are two possible values of power consumption for given voltage levels, corresponding to two branches of power flow equation solutions. In this representation, only the lower branch is stable.

The method can be obviously generalized to more complicated situations with less trivial grid topologies and more sophisticated individual load models. As discussed before, the traditional Gröbner basis construction algorithms may result in high-order implicit equations describing the models, so either numerical approximation of intermediate results or utilization of more advanced sparsity-exploiting elimination schemes is necessary to scale the approach to large systems.

Another important application of the Gröbner basis approach is the analysis of bifurcations in power system models. Overloading the power system beyond acceptable limits typically leads to disappearance of equilibrium or loss of stability. Understanding the loadability limits is critical for secure operation of power systems. Mathematically, disappearance of power flow solutions happens through the saddle-node bifurcation which occurs when the power flow




Fig. 2. Loadability limit boundaries defined by equation (19) with $V = 0.9 p.u.$ (blue), $V = 1.0 p.u.$ (orange), $V = 1.1 p.u.$ (green).

equations' Jacobian matrix becomes singular. As the power flow equations have a polynomial form, the Jacobian can be also represented as matrix polynomial $J(x, p)$ depending both on the variables and external parameters. Given this representation, one can introduce the singularity condition through two additional equations $Jz = 0$ and $z^T z = 1$ where z is the zero eigenvector of the Jacobian. The combination of power flow equations and these two singularity conditions describes the algebraic saddle-node bifurcation manifold.

For the two-bus example described above, the system of equations (4)–(9) is complemented with the following representation of the matrix singularity conditions:

$$z_1 = 0, \quad (12)$$

$$z_2 = 0, \quad (13)$$

$$z_3 - z_5 i_d + z_6 i_q = 0, \quad (14)$$

$$z_4 - z_6 i_d - z_5 i_q = 0, \quad (15)$$

$$\frac{z_3}{4} + \frac{z_4}{4} - z_5 V_d - z_6 V_q - V z_1 = 0, \quad (16)$$

$$\frac{z_4}{4} - \frac{z_3}{4} + z_6 V_d - z_5 V_q + V z_2 = 0, \quad (17)$$

$$z_1^2 + z_2^2 + z_3^2 + z_4^2 + z_5^2 + z_6^2 = 1. \quad (18)$$

The first equation of Gröbner basis with the ordering $i_d \prec i_q \prec V_d \prec V_q \prec Q \prec P \prec z_1 \prec \dots \prec z_6 \prec V \prec P_L \prec Q_L$ takes the form

$$P_L^2 - 2P_L Q_L + Q_L^2 + 4V^2 P_L + 4V^2 Q_L - 4V^4 = 0, \quad (19)$$

that describes the ellipsoidal curve corresponding to loadability limits in terms of P_L , Q_L , and terminal voltage V . The resulting boundaries are presented in Fig. 2

Similar techniques can be extended to more complicated problems. For instance, inequality constraints responsible for

feasibility can be introduced in the same framework via slack variable approaches. For example, the voltage constraint $V_d^2 + V_q^2 \geq (V^{min})^2$ can be rewritten in equality form with additional slack variable s introduced as $V_d^2 + V_q^2 = (V^{min})^2 + s^2$. This equation has a solution only when the voltage level satisfies the original inequality constraint. Therefore, the bifurcations of this extended system will define the boundary of the feasibility region where the solution exists and also satisfies the physical limits.

Gröbner basis approaches can be also applied to dynamic models of power systems. For small-signal stability analysis, the linearized equations of motion $\dot{x} = A(p)x$ depend on the operating conditions described by the parameter set p . The small-signal stability condition can be expressed as $A(p)(\mathbf{u} + \mathbf{jv}) = (\mu + \mathbf{jv})(\mathbf{u} + \mathbf{jv})$ with extra constraints $\mathbf{u}^\top \mathbf{u} + \mathbf{v}^\top \mathbf{v} = 1$ and $\mu \leq 0$. Here, the vector $(\mathbf{u} + \mathbf{jv})$ is the eigenvector of the linearized system matrix, and μ, ν are the real and imaginary parts of the corresponding eigenvalue. The condition $\nu \leq 0$, which can be also expressed as $\nu + s^2 = 0$ after the slack variable introduction trick, expresses the small-signal stability criterion. The resulting system defines an algebraic manifold corresponding to stable operating conditions. Elimination of the \mathbf{u}, \mathbf{v} and μ, ν variables defines the manifold in parameter \mathbf{p} space where the system possess a stable equilibrium.

Recently, Gröbner basis techniques have been applied to power system models in the context of the power flow reversal problem [32], [33]. Introduction of renewable generation on a distribution grid may result in reversal of power flow and export of power to the transmission systems. These new regimes, which are not common to traditional power systems, are characterized by multiple branches of solutions. Although usually not suitable for normal operations, these new equilibrium points may compromise the normal post-fault restoration of the system and result in the system being trapped in an undesirable stable equilibrium. The structure of the new solutions, precise conditions of their appearance, and their impact on power system stability and security is still poorly understood and requires more intensive investigation.

V. MOMENT/SUM-OF-SQUARES RELAXATIONS OF THE POWER FLOW EQUATIONS

Advances in computational methods related to the power flow equations have the potential to improve solution techniques for many different problems. Motivated by the extensive optimization needs envisioned for future power systems, a variety of convex relaxations and approximations of the power flow equations have recently been developed. These relaxations and approximations can facilitate the optimization of broader classes of systems and operating conditions than traditional methods. Further, emerging computational tools have capabilities that surpass those in traditional solution techniques, such as providing a measure of solution quality, certifying problem infeasibility, and, in many cases, provably obtaining the global optimum. This section reviews recent work in developing a hierarchy of *moment/sum-of-squares* (MSOS) relaxations of the power flow equations.

Most of the work on convex relaxations of the power flow equations has focused on the optimal power flow (OPF) problem (e.g., [36], [67]–[74]). The OPF problem determines a minimum cost operating point for an electric power system subject to both network constraints (i.e., the power flow equations) and engineering limits (e.g., bounds on voltage magnitudes, active and reactive power injections, and line flows). This section presents the MSOS relaxations in terms of the OPF problem; however, note that the MSOS formulations could be applied to a variety of other power system optimization problems (e.g., transmission expansion planning [75], [76], voltage regulation [77], state estimation [78], and calculating voltage stability margins [12]–[14]). Further, when applied to an optimization problem with a feasible space defined by polynomial equality constraints and a constant objective function, MSOS relaxations with sufficiently high relaxation order can find all solutions to the polynomials [53]. This approach could be applied to find all power flow solutions for small systems.

Formulating the power flow equations as a system of polynomials enables the application of the Lasserre hierarchy for polynomial optimization problems [53]. The first-order MSOS relaxation in the Lasserre hierarchy is equivalent to the semidefinite programming (SDP) relaxation in [67]; higher-order MSOS relaxations in the Lasserre hierarchy take the form of SDPs that generalize the relaxation in [67].

Directly applying the Lasserre hierarchy to the OPF problem has been explored in [30], [79], [80]. Related work includes exploiting sparsity and selectively applying the higher-order constraints to solve large-scale problems [81], [82]. Other related work develops hierarchies that leverage the *complex structure* of the power flow equations [83] and employ a mix of semidefinite and second-order cone programming (SOCP) to enforce the higher-order constraints in the MSOS relaxations [84]. This section will review the development of the MSOS relaxations from the Lasserre hierarchy in [30], [79], [80] and summarize the related work on computational improvements in [81]–[84].

A. Overview of the Optimal Power Flow Problem

We first present the non-convex optimal power flow problem, starting with the introduction of notation in addition to that used for the power flow problem in Section II. Superscripts “max” and “min” denote specified upper and lower limits and buses without generators have maximum and minimum generation set to zero.

In terms of complex voltages, the active and reactive power generation $f_{P_i}(V)$ and $f_{Q_i}(V)$, respectively, are polynomials in V and \bar{V} :

$$f_{P_i}(V) := P_{D_i} + \operatorname{Re} \left(V_i \sum_{k=1}^n \bar{Y}_{ik} \bar{V}_k \right) \quad (20a)$$

$$f_{Q_i}(V) := Q_{D_i} + \operatorname{Im} \left(V_i \sum_{k=1}^n \bar{Y}_{ik} \bar{V}_k \right) \quad (20b)$$

where $P_{D_i} + \mathbf{j}Q_{D_i}$ are specified load demands. Squared

voltage magnitudes are

$$f_{V_i}(V) := V_i \bar{V}_i. \quad (21)$$

The OPF problem in terms of complex voltages V is

$$\min_V \sum_{i \in \mathcal{G}} c_i f_{P_i}(V) \quad \text{subject to} \quad (22a)$$

$$P_{G_i}^{\min} \leq f_{P_i}(V) \leq P_{G_i}^{\max} \quad \forall i \in \mathcal{N} \quad (22b)$$

$$Q_{G_i}^{\min} \leq f_{Q_i}(V) \leq Q_{G_i}^{\max} \quad \forall i \in \mathcal{N} \quad (22c)$$

$$(V_i^{\min})^2 \leq f_{V_i}(V) \leq (V_i^{\max})^2 \quad \forall i \in \mathcal{N} \quad (22d)$$

where $c \in \mathbb{R}^n$ is a linear cost of active power generation.⁵ Note that buses without generators have $P_{G_i}^{\max} = P_{G_i}^{\min} = Q_{G_i}^{\max} = Q_{G_i}^{\min} = 0$.

Splitting real and imaginary parts of (20)–(21) and using rectangular voltage coordinates yields quadratic polynomials in real variables V_d and V_q :

$$g_{P_i}(V_d, V_q) := V_{di} \sum_{k=1}^n (\mathbf{G}_{ik} V_{dk} - \mathbf{B}_{ik} V_{qk}) + V_{qi} \sum_{k=1}^n (\mathbf{B}_{ik} V_{dk} + \mathbf{G}_{ik} V_{qk}) + P_{Di}, \quad (23a)$$

$$g_{Q_i}(V_d, V_q) := V_{di} \sum_{k=1}^n (-\mathbf{B}_{ik} V_{dk} - \mathbf{G}_{ik} V_{qk}) + V_{qi} \sum_{k=1}^n (\mathbf{G}_{ik} V_{dk} - \mathbf{B}_{ik} V_{qk}) + Q_{Di}. \quad (23b)$$

Squared voltage magnitudes are given by

$$g_{V_i}(V_d, V_q) := V_{di}^2 + V_{qi}^2. \quad (24)$$

The OPF problem in terms of real voltage components V_d and V_q is

$$\min_{V_d, V_q} \sum_{i \in \mathcal{G}} c_i g_{P_i}(V_d, V_q) \quad \text{subject to} \quad (25a)$$

$$P_{G_i}^{\min} \leq g_{P_i}(V_d, V_q) \leq P_{G_i}^{\max} \quad \forall i \in \mathcal{N} \quad (25b)$$

$$Q_{G_i}^{\min} \leq g_{Q_i}(V_d, V_q) \leq Q_{G_i}^{\max} \quad \forall i \in \mathcal{N} \quad (25c)$$

$$(V_i^{\min})^2 \leq g_{V_i}(V_d, V_q) \leq (V_i^{\max})^2 \quad \forall i \in \mathcal{N} \quad (25d)$$

Since the power flow equations are functions of angle differences, both formulations of the OPF problem (22) and (25) have a degeneracy in the voltage angle. Similar to the slack bus in the power flow equations, this degeneracy is accounted for by arbitrarily fixing the angle reference at a specified bus. This can either be accomplished by rotating the voltage vectors from the solutions to the MSOS relaxations such that the angle reference is satisfied (as is done here) or by enforcing the additional constraints $\frac{V_1 - \bar{V}_1}{2j} = 0$ and $V_{q1} = 0$ in (22) and (25), respectively, where it is assumed that bus 1 has a fixed angle reference of 0° .

⁵The MSOS relaxations are applicable to more general OPF formulations that include, e.g., line-flow limits, quadratic and piecewise-linear generator costs, and multiple generators per bus [69], [72], [81]

B. Applying the Lasserre Hierarchy to the OPF Problem

Lasserre developed a hierarchy of increasingly tighter MSOS relaxations of polynomial optimization problems in real variables [53].⁶ MSOS relaxations from the Lasserre hierarchy, which take the form of semidefinite programs, converge to the global optimum of a polynomial optimization problem with increasing relaxation order. We denote the order- γ relaxation applied to the OPF problem in real variables V_d and V_q as $\text{MSOS}_\gamma\text{-}\mathbb{R}$. This section reviews [30], [79], [80], which formulate MSOS relaxations for the OPF problem (25) in real variables.

Development of the relaxations require several definitions. Group the decision variables V_d and V_q into a vector \hat{x} :

$$\hat{x} := [V_{d1} \ \dots \ V_{dn} \ V_{q1} \ \dots \ V_{qn}]^\top. \quad (26)$$

Define a vector x_γ consisting of all monomials of the voltage components V_d and V_q up to the relaxation order γ :

$$x_\gamma := [1 \ V_{d1} \ \dots \ V_{qn} \ V_{d1}^2 \ V_{d1}V_{d2} \ \dots \ \dots \ V_{qn}^2 \ V_{d1}^3 \ V_{d1}^2V_{d2} \ \dots \ V_{qn}^\gamma]^\top. \quad (27)$$

A monomial is defined using a vector $\alpha \in \mathbb{N}^{2n}$ of exponents: $\hat{x}^\alpha := V_{d1}^{\alpha_1} V_{d2}^{\alpha_2} \dots V_{qn}^{\alpha_{2n}}$. A polynomial is $h(\hat{x}) := \sum_{\alpha \in \mathbb{N}^{2n}} h_\alpha \hat{x}^\alpha$, where h_α is the real scalar coefficient corresponding to the monomial \hat{x}^α .

Define a linear functional $L_y \{h\}$ which replaces the monomials \hat{x}^α in a polynomial $h(\hat{x})$ with real scalar variables y_α :

$$L_y \{h\} := \sum_{\alpha \in \mathbb{N}^{2n}} g_\alpha y_\alpha. \quad (28)$$

For a matrix $h(\hat{x})$, $L_y \{h\}$ is applied componentwise to each element of $h(\hat{x})$.

Consider, e.g., the vector $\hat{x} = [V_{d1} \ V_{d2} \ V_{q1} \ V_{q2}]^\top$ corresponding to the voltage components of a two-bus system. Consider also the polynomial $(V_2^{\max})^2 - g_{V_2}(\hat{x}) = (V_2^{\max})^2 - V_{d2}^2 - V_{q2}^2$. (The constraint $(V_2^{\max})^2 - g_{V_2}(\hat{x}) \geq 0$ forces the voltage magnitude at bus 2 to be less than or equal to V_2^{\max} .) Then $L_y \{(V_2^{\max})^2 - g_{V_2}\} = (V_2^{\max})^2 y_{0000} - y_{0200} - y_{0002}$. Thus, $L_y \{g\}$ converts a polynomial $(V_2^{\max})^2 - g_{V_2}(\hat{x})$ to a linear function of y .

The MSOS relaxations add additional variables and constraints that are redundant in the original problem but serve to strengthen the relaxation. To simplify the notation, we group all the constraints in (25) into a vector $g(\hat{x}) \in \mathbb{R}^{6n}$:

⁶The primal form of these relaxations, which is presented here, is derived using truncated *moment* sequences. The dual form is interpreted as a *sum-of-squares* program. Hence, the terminology ‘‘MSOS’’ relaxations. There is zero duality gap between the primal and dual forms of the MSOS relaxations for OPF problems [85].

$$g(\hat{x}) := \begin{bmatrix} P_{G1}^{\max} - g_{P1} \\ \vdots \\ P_{Gn}^{\max} - g_{Pn} \\ g_{P1} - P_{G1}^{\min} \\ \vdots \\ g_{Pn} - P_{Gn}^{\min} \\ Q_{G1}^{\max} - g_{Q1} \\ \vdots \\ Q_{Gn}^{\max} - g_{Qn} \\ g_{Q1} - Q_{G1}^{\min} \\ \vdots \\ g_{Qn} - Q_{Gn}^{\min} \\ (V_1^{\max})^2 - g_{V1} \\ \vdots \\ (V_n^{\max})^2 - g_{Vn} \\ g_{V1} - (V_1^{\min})^2 \\ \vdots \\ g_{Vn} - (V_n^{\min})^2 \end{bmatrix}. \quad (29)$$

The order- γ relaxation $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ can be derived from a rank-constrained optimization problem related to (25):

$$\min_{\hat{x}} \sum_{k \in \mathcal{G}} c_k g_{P_k}(\hat{x}) \quad \text{subject to} \quad (30a)$$

$$g_i(\hat{x}) x_{\gamma-1} x_{\gamma-1}^{\top} \succcurlyeq 0 \quad i = 1, \dots, 6n \quad (30b)$$

$$x_{\gamma} x_{\gamma}^{\top} \succcurlyeq 0 \quad (30c)$$

where \succcurlyeq indicates positive semidefiniteness of the corresponding matrix and $\gamma \geq 1$ is a specified integer which will denote the relaxation order. The rank-one matrices $x_{\gamma-1} x_{\gamma-1}^{\top}$ and $x_{\gamma} x_{\gamma}^{\top}$ are positive semidefinite by construction. Thus, the constraints $g_i(\hat{x}) x_{\gamma-1} x_{\gamma-1}^{\top} \succcurlyeq 0$ and $g_i(\hat{x}) \geq 0$ are redundant and (30c) is unnecessary. The matrices $g_i(\hat{x}) x_{\gamma-1} x_{\gamma-1}^{\top} \succcurlyeq 0$ and $x_{\gamma} x_{\gamma}^{\top} \succcurlyeq 0$ are composed of polynomials and monomials, respectively, which have degree at most 2γ .

The relaxation $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ is formed by applying the linear functional $L_y\{\cdot\}$ to the constraints and objective function in (30) in order to obtain an SDP in terms of the *lifted* variables y :

$$\min_y \sum_{k \in \mathcal{G}} c_k L_y\{g_{P_k}(\hat{x})\} \quad \text{subject to} \quad (31a)$$

$$L_y\{g_i(\hat{x}) x_{\gamma-1} x_{\gamma-1}^{\top}\} \succcurlyeq 0 \quad i = 1, \dots, 6n \quad (31b)$$

$$L_y\{x_{\gamma} x_{\gamma}^{\top}\} \succcurlyeq 0 \quad (31c)$$

$$y_{0\dots 0} = 1. \quad (31d)$$

In Lasserre's terminology [53], (31b) constrains *localizing matrices* and (31c) constrains the *moment matrix* for $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$. See [30] and [86] for the localizing and moment matrices for small example OPF problems. Note that (31d) results from the fact that $\hat{x}^0 = 1$.

Since x_0 is the scalar 1, the localizing constraints (31b) for $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ are in fact non-negativity constraints $L_y\{g_i(\hat{x})\} \geq 0$. Thus, $\text{MSOS}_1\text{-}\mathbb{R}$ is equivalent to the SDP relaxation in [67], and $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ generalizes the relaxation of [67] for $\gamma > 1$.

As a relaxation, the optimal objective value for $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ lower bounds the globally optimal objective value for the OPF problem. A solution to $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ which satisfies

$$\text{rank}(L_y\{\hat{x}\hat{x}^{\top}\}) \leq 2 \quad (32)$$

indicates that the relaxation is *exact*.⁷ The globally optimal voltage phasor solution V^* to the OPF problem can be extracted using a spectral decomposition. Let λ and η denote a non-zero eigenvalue and corresponding unit-length eigenvector, respectively, of the matrix $L_y\{\hat{x}\hat{x}^{\top}\}$. Then $V^* = \sqrt{\lambda}(\eta_{1:n} + \mathbf{j}\eta_{n+1:2n})$, rotated such that $\text{Im}(V_1^*) = 0$, where subscripts indicate vector entries in MATLAB notation. If the rank condition (32) is not satisfied, increasing the relaxation order to $\gamma + 1$ will tighten the relaxation and may yield the globally optimal solution. The results in [30], [79], [80], [86] demonstrate that $\text{MSOS}_2\text{-}\mathbb{R}$ is capable of globally solving many small problems for which $\text{MSOS}_1\text{-}\mathbb{R}$ (or, equivalently, the SDP relaxation in [67]) fails to be exact.

C. Computational Improvements

Application to large OPF problems requires addressing the computational scaling challenges inherent to the MSOS relaxations. For an n -bus system, the size of the moment matrix (31c) for $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ is $(2n + \gamma)! / ((2n)! \gamma!)$. For example, $n = 10$ and $\gamma = 3$ correspond to a moment matrix of size $1,771 \times 1,771$. This limits application of the “dense” formulation described in Section V-B to systems with at most approximately ten buses. We next summarize three approaches for improving the computational tractability of the MSOS relaxations: 1) exploiting sparsity and selectively applying the higher-order relaxation constraints to specific “problematic” buses, 2) using a hierarchy that exploits the complex structure of the OPF problem, and 3) enforcing the first-order constraints with the SDP formulation while using an SOCP relaxation of the higher-order constraints.

1) *Exploiting Sparsity and Selectively Applying the Higher-Order Constraints*: As is common in power system optimization, exploiting sparsity has the potential to improve the computational tractability of the MSOS relaxations. A method for exploiting sparsity in relaxations of general polynomial optimization problems [87] can be directly applied to the MSOS relaxations of the OPF problem. This approach uses a matrix completion theorem [88] to decompose the single large positive semidefinite constraints in (31b) and (31c) into constraints on many smaller submatrices in a manner that depends on the so-called *chordal sparsity* of

⁷A rank less than or equal to 2 (rather than 1) indicates global optimality of a solution to (31) due to the degeneracy resulting from the lack of an angle reference specification in (25). Enforcing the additional constraint $V_{q1} = 0$ or removing V_{q1} from the formulation would specify bus 1 as the angle reference, thus eliminating this degeneracy and resulting in a global optimality condition of $\text{rank}(L_y\{\hat{x}\hat{x}^{\top}\}) = 1$.

the power system network. Related approaches applied to the SDP relaxation of [67] (and therefore also $\text{MSOS}_1\text{-}\mathbb{R}$) enable solution of problems with thousands of buses [68], [69].

Naïvely applying the chordal-sparsity approach to the higher-order relaxations is less successful; only systems with at most approximately 40 buses are computationally tractable for $\text{MSOS}_2\text{-}\mathbb{R}$. The key insight needed to scale the higher-order MSOS relaxations to larger problem is that the computationally intensive higher-order constraints are only needed for certain buses. By selectively applying the higher-order constraints at “problematic” buses, [81] and [82] are able to globally solve OPF problems with thousands of buses.⁸ Reference [81] describes an iterative method for identifying the problematic buses using a “power injection mismatch” heuristic. See [89] for a computational analysis of the key parameter in this sparsity-exploiting approach (i.e., the number of additional buses with higher-order constraints applied at each iteration).

2) *Complex Hierarchy*: The approach in Section V-B converts the OPF problem from a formulation with complex variables (22) to a formulation with real variables (25) and then applies the Lasserre hierarchy. An alternative approach recognizes that, in general, the operations of converting to the real representation and applying the Lasserre hierarchy are not commutative. For the OPF problem, it is often computationally advantageous to directly build a *complex* moment/sum-of-squares hierarchy, where we denote the order- γ relaxation as $\text{MSOS}_\gamma\text{-}\mathbb{C}$, and then convert to real variables before passing the formulation to the SDP solver. This section briefly describes the complex moment/sum-of-squares hierarchy which was first proposed in [83].

This section adopts notation and follows the development of the real moment/sum-of-squares hierarchy in Section V-B. A complex monomial is defined using two vectors of exponents $\alpha, \beta \in \mathbb{N}^n$: $V^\alpha \bar{V}^\beta := V_1^{\alpha_1} \dots V_n^{\alpha_n} \bar{V}_1^{\beta_1} \dots \bar{V}_n^{\beta_n}$. A polynomial $h(V) := \sum_{\alpha, \beta \in \mathbb{N}^n} h_{\alpha, \beta} V^\alpha \bar{V}^\beta$, where $h_{\alpha, \beta}$ is the complex scalar coefficient corresponding to the monomial $V^\alpha \bar{V}^\beta$. Since $h(V)$ is a real quantity, $\overline{h_{\alpha, \beta}} = h_{\beta, \alpha}$.

Define a linear functional $\hat{L}_{\hat{y}}\{h\}$ which replaces the monomials $V^\alpha \bar{V}^\beta$ in a polynomial $h(V)$ with complex scalar variables $\hat{y}_{\alpha, \beta}$:

$$\hat{L}_{\hat{y}}\{h\} := \sum_{\alpha, \beta \in \mathbb{N}^n} h_{\alpha, \beta} \hat{y}_{\alpha, \beta}. \quad (33)$$

For a matrix $h(V)$, $\hat{L}_{\hat{y}}\{h\}$ is applied componentwise.

Consider, e.g., the vector $V = [V_1 \ V_2]^\top$ of complex voltages for a two-bus system and the polynomial $(V_2^{\max})^2 - f_{V_2}(V) = (V_2^{\max})^2 - V_2 \bar{V}_2$. (The constraint $(V_2^{\max})^2 - f_{V_2}(V) \geq 0$ forces the voltage magnitude at bus 2 to be less than or equal to V_2^{\max} .) Then $\hat{L}_{\hat{y}}\{(V_2^{\max})^2 - f_{V_2}(V)\} = (V_2^{\max})^2 \hat{y}_{00,00} - \hat{y}_{01,01}$. Thus, $\hat{L}_{\hat{y}}\{h\}$ converts a polynomial $h(V)$ to a linear function of \hat{y} .

⁸More so than computational speed, numerical convergence limits the performance of the higher-order relaxations. Reference [82] presents a method for preprocessing the OPF problem data to eliminate “low-impedance” lines in order to improve convergence characteristics of the SDP solver.

For the order- γ relaxation, define a vector z_γ consisting of all monomials of the voltages up to order γ without complex conjugate terms (i.e., $\beta = 00 \dots 0$):

$$z_\gamma := \begin{bmatrix} 1 & V_1 & \dots & V_n & V_1^2 & V_1 V_2 & \dots \\ & & & & \dots & V_n^2 & V_1^3 & V_1^2 V_2 & \dots & V_n^\gamma \end{bmatrix}^\top. \quad (34)$$

We again simplify the notation by grouping all the constraints in (22) into a vector $f(V) \in \mathbb{R}^{6n}$ in the same manner as in (29).

The order- γ relaxation in the complex hierarchy, $\text{MSOS}_\gamma\text{-}\mathbb{C}$, can be derived from a rank-constrained optimization problem related to (22):

$$\min_V \sum_{k \in \mathcal{G}} c_k f_{Pk}(V) \quad \text{subject to} \quad (35a)$$

$$f_i(V) z_{\gamma-1} z_{\gamma-1}^H \succeq 0 \quad i = 1, \dots, 6n \quad (35b)$$

$$z_\gamma z_\gamma^H \succeq 0 \quad (35c)$$

where $(\cdot)^H$ denotes the complex conjugate transpose. The rank-one Hermitian matrices $z_{\gamma-1} z_{\gamma-1}^H$ and $z_\gamma z_\gamma^H$ are positive semidefinite by construction. Thus, the constraints $f_i(V) z_{\gamma-1} z_{\gamma-1}^H \succeq 0$ and $f_i(V) \geq 0$ are redundant and (35c) is unnecessary. The matrices $f_i(V) z_{\gamma-1} z_{\gamma-1}^H \succeq 0$ and $x_\gamma x_\gamma^H \succeq 0$ are composed of complex polynomials and monomials, respectively, which have degree at most 2γ (i.e., all monomials $V^\alpha \bar{V}^\beta$ satisfy $|\alpha| + |\beta| \leq 2\gamma$, where $|\cdot|$ indicates the one-norm).

The relaxation $\text{MSOS}_\gamma\text{-}\mathbb{C}$ is formed by applying the linear functional $\hat{L}_{\hat{y}}\{\cdot\}$ to the constraints and objective function in (35) in order to obtain an SDP in terms of the lifted complex variables \hat{y} :

$$\min_{\hat{y}} \sum_{k \in \mathcal{G}} c_k \hat{L}_{\hat{y}}\{f_{Pk}(V)\} \quad \text{subject to} \quad (36a)$$

$$\hat{L}_{\hat{y}}\{f_i(V) z_{\gamma-1} z_{\gamma-1}^H\} \succeq 0 \quad i = 1, \dots, 6n \quad (36b)$$

$$\hat{L}_{\hat{y}}\{z_\gamma z_\gamma^H\} \succeq 0 \quad (36c)$$

$$\hat{y}_{0 \dots 0, 0 \dots 0} = 1. \quad (36d)$$

Mirroring Lasserre’s terminology [53], (36b) constrains complex localizing matrices and (36c) constrains the complex moment matrix for $\text{MSOS}_\gamma\text{-}\mathbb{C}$. See [89] for the complex localizing and moment matrices for small example problems.

Similar to $\text{MSOS}_\gamma\text{-}\mathbb{R}$, a solution to $\text{MSOS}_\gamma\text{-}\mathbb{C}$ that satisfies the rank condition

$$\text{rank}(\hat{L}_{\hat{y}}\{V V^H\}) = 1 \quad (37)$$

indicates that the relaxation is *exact* and the globally optimal voltage phasor solution V^* to the OPF problem can be extracted using a spectral decomposition. Let $\hat{\lambda}$ and $\hat{\eta}$ denote the non-zero eigenvalue and corresponding unit-length eigenvector, respectively, of the matrix $\hat{L}_{\hat{y}}\{V V^H\}$. Then $V^* = \sqrt{\hat{\lambda}} \hat{\eta}$, rotated so that $\text{Im}(V_1^*) = 0$. If the rank condition (37) is not satisfied, increasing the relaxation order to $\gamma + 1$ will tighten the relaxation and may yield the globally optimal solution. The second-order complex

hierarchy globally solves many problems for which the first-order relaxation is not exact.

Since z_0 is the scalar 1, the localizing constraints (36b) for $\text{MSOS}_{\gamma}\text{-}\mathbb{C}$ are in fact non-negativity constraints $\hat{L}_{\hat{y}}\{f_i(V)\} \geq 0$. It is proven in [83] that $\text{MSOS}_1\text{-}\mathbb{C}$ and $\text{MSOS}_1\text{-}\mathbb{R}$ (and therefore also the SDP relaxation of [67]) have the same optimal objective values. However, $\text{MSOS}_1\text{-}\mathbb{C}$ typically has computational advantages over $\text{MSOS}_1\text{-}\mathbb{R}$ [83].

Another characteristic of the complex hierarchy, as proven in [83], is a sum-of-squares interpretation of the dual problem, with zero duality gap between the primal and dual relaxations for the OPF problem.

As proven in [83], the optimal objective value from the real hierarchy is at least as tight as that from the complex hierarchy, and there exist general complex polynomial optimization problems for which the real hierarchy is tighter. However, [83] conjectures that the real and complex hierarchies are equally tight for a class of problems modeling oscillatory phenomena (which includes the OPF problem) augmented with a redundant “sphere constraint”.

The computational advantage of the complex hierarchy is most evident when comparing the moment matrix sizes between $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ and $\text{MSOS}_{\gamma}\text{-}\mathbb{C}$. For an n -bus system, the size of the moment matrix (36c) for $\text{MSOS}_{\gamma}\text{-}\mathbb{C}$ (converted to real representation for input to the solver [90, Ex. 4.42]) is $2((n + \gamma)!)/(n!\gamma!)$, which is significantly smaller than $(2n + \gamma)!/((2n)!\gamma!)$ for $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$. For example, $n = 10$ and $\gamma = 3$ correspond to matrices of size $1,771 \times 1,771$ and 572×572 for the real and complex hierarchies, respectively. Note that the sparsity-exploiting approach applied to $\text{MSOS}_{\gamma}\text{-}\mathbb{R}$ [81] can be adopted to $\text{MSOS}_{\gamma}\text{-}\mathbb{C}$ [83]. The results in [83] demonstrate that computational speed improvements for the complex hierarchy vs. the real hierarchy can exceed an order of magnitude for some large test cases.

3) *Mixed SDP/SOCP Hierarchy*: First proposed in [84], a relaxation of the Lasserre hierarchy that mixes SDP and SOCP constraints facilitates the development of a related hierarchy with tightness and computational burden between $\text{MSOS}_1\text{-}\mathbb{R}$ and $\text{MSOS}_2\text{-}\mathbb{R}$.⁹ This enables exploitation of the intuition that the second-order relaxation is often more than necessary for global solution of many OPF problems.

A necessary (but not sufficient) condition for a matrix to be positive semidefinite takes the form of an SOCP constraint. Specifically, a generic symmetric, positive semidefinite matrix \mathbf{W} satisfies

$$\mathbf{W}_{ii}\mathbf{W}_{kk} \geq |\mathbf{W}_{ik}|^2 \quad \forall \{(i, k) \mid k > i\} \quad (38)$$

In [70], the SOCP constraint (38) is applied to the first-order relaxation $\text{MSOS}_1\text{-}\mathbb{C}$. While this significantly reduces the computational burden compared to using SDP constraints, the SOCP relaxation in [70] typically only yields the global solution to a limited set of OPF problems.¹⁰

⁹Future work includes extending the mixed SDP/SOCP hierarchy reported in this section to the complex hierarchy $\text{MSOS}_{\gamma}\text{-}\mathbb{C}$.

¹⁰The SOCP relaxation in [70] is guaranteed to globally solve OPF problems with radial networks that satisfy certain non-trivial technical conditions, but generally fails to yield the global optimum for mesh network topologies.

Conversely, the mixed SDP/SOCP relaxation proposed in [84] formulates the first-order relaxation $\text{MSOS}_1\text{-}\mathbb{R}$ with SDP constraints. This alone is sufficient to globally solve many OPF problems [67], [69]. When the solution to $\text{MSOS}_1\text{-}\mathbb{R}$ does not satisfy the rank condition (32), the mixed SDP/SOCP relaxation applies the SOCP formulation (38) to the entries of the localizing and moment matrices which correspond to the higher-order constraints rather than use the computationally intensive SDP formulation. Thus, the proposed mixed SDP/SOCP relaxation forms a “middle ground” between the first- and higher-order moment relaxations.

The mixed SDP/SOCP relaxations are generally not as tight as those which use only SDP constraints; there exist OPF problems for which $\text{MSOS}_2\text{-}\mathbb{R}$ is exact, but low-order mixed SDP/SOCP relaxations only provide a strict lower bound on the optimal objective value [86]. However, results for a variety of systems with up to several hundred buses demonstrate a significant computational speed improvement for some problems (e.g., a factor of 18.7 for one test case).

VI. CONCLUSION

After briefly reviewing both canonical and emerging computational methods to solve the power flow equations, this tutorial paper has presented overviews of three methods based on algebraic geometry: Numerical Polynomial Homotopy Continuation, Gröbner Basis, and Moment/Sum-of-Squares relaxations. We anticipate that this tutorial paper will motivate both power systems researchers and computational mathematicians to further explore the capabilities of these methods with respect to power systems problems as well as to enhance the computational capabilities of these methods.

REFERENCES

- [1] W. Tinney and C. Hart, “Power Flow Solution by Newton’s Method,” *IEEE Trans. Power App. Sys.*, vol. PAS-86, no. 11, pp. 1449–1460, Nov. 1967.
- [2] B. Stott and O. Alsac, “Fast Decoupled Load Flow,” *IEEE Trans. Power App. Sys.*, vol. PAS-93, no. 3, pp. 859–869, May 1974.
- [3] A. Glimm and G. Stagg, “Automatic Calculation of Load Flows,” *Trans. Am. Inst. Electr. Eng. Part III: Power App. Syst.*, vol. 3, no. 76, pp. 817–825, 1957.
- [4] J. Thorp and S. Naqavi, “Load Flow Fractals,” in *IEEE 28th Ann. Conf. Decis. Contr. (CDC)*, Dec. 1989.
- [5] J. Thorp, S. Naqavi, and N. Chiang, “More Load Flow Fractals,” in *IEEE 29th Ann. Conf. Decis. Contr. (CDC)*, Dec. 1990, pp. 3028–3030.
- [6] S. Iwamoto and Y. Tamura, “A Load Flow Calculation Method for Ill-Conditioned Power Systems,” *IEEE Trans. Power App. Syst.*, vol. PAS-100, no. 4, pp. 1736–1743, Apr. 1981.
- [7] D. Bromberg, M. Jereminov, X. Li, G. Hug, and L. Pileggi, “An Equivalent Circuit Formulation of the Power Flow Problem with Current and Voltage State Variables,” in *IEEE Eindhoven PowerTech*, June 2015.
- [8] A. Trias, “The Holomorphic Embedding Load Flow Method,” in *IEEE PES General Meeting*, July 2012.
- [9] K. Dvijotham, S. Low, and M. Chertkov, “Convexity of Energy-Like Functions: Theoretical Results and Applications to Power System Operations,” *arXiv:1501.04052*, 2015.
- [10] K. Dvijotham, M. Chertkov, and S. Low, “A Differential Analysis of the Power Flow Equations,” *IEEE 54th Ann. Conf. Decis. Contr. (CDC)*, Dec. 2015.
- [11] R. Madani, J. Lavaei, and R. Baldick, “Convexification of Power Flow Problem over Arbitrary Networks,” *IEEE 54th Ann. Conf. Decis. Contr. (CDC)*, Dec. 2015.

- [12] D. Molzahn, B. Lesieutre, and C. DeMarco, "A Sufficient Condition for Power Flow Insolubility With Applications to Voltage Stability Margins," *IEEE Trans. Power Syst.*, vol. 28, no. 3, pp. 2592–2601, 2013.
- [13] D. Molzahn, V. Dawar, B. Lesieutre, and C. DeMarco, "Sufficient Conditions for Power Flow Insolubility Considering Reactive Power Limited Generators with Applications to Voltage Stability Margins," in *IREP Symp.*, Aug. 25-30 2013.
- [14] D. Molzahn, I. Hiskens, and B. Lesieutre, "Calculation of Voltage Stability Margins and Certification of Power Flow Insolubility using Second-Order Cone Programming," in *47th Hawaii Int. Conf. Syst. Sci. (HICSS)*, Jan. 5-8, 2016.
- [15] M. Ilic, "Network Theoretic Conditions for Existence and Uniqueness of Steady State Solutions to Electric Power Circuits," in *IEEE Int. Symp. Circuits Syst. (ISCAS)*, May 1992.
- [16] F. Dörfler and F. Bullo, "Novel Insights into Lossless AC and DC Power Flow," in *IEEE PES General Meeting*, July 2013.
- [17] J. Simpson-Porco, F. Dörfler, and F. Bullo, "A Solvability Condition for Reactive Power Flow," *IEEE 54th Ann. Conf. Decis. Control (CDC)*, pp. 2013–2017, Dec. 15-18, 2015.
- [18] C. Tavora and O. J. Smith, "Equilibrium Analysis of Power Systems," *IEEE Trans. Power App. Syst.*, vol. PAS-91, no. 3, pp. 1131–1137, 1972.
- [19] A. Klos and A. Kerner, "The Non-Uniqueness of Load Flow Solution," in *5th Power Syst. Comput. Conf. (PSCC)*, 1975.
- [20] J. Baillieul and C. Byrnes, "Geometric Critical Point Analysis of Lossless Power System Models," *IEEE Trans. Circuits Syst.*, vol. 29, no. 11, 1982.
- [21] T.-Y. Li, T. Sauer, and J. A. Yorke, "Numerical Solution of a Class of Deficient Polynomial Systems," *SIAM J. Numerical Analy.*, vol. 24, no. 2, pp. 435–451, 1987.
- [22] A. Klos and J. Wojcicka, "Physical Aspects of the Nonuniqueness of Load Flow Solutions," *Int. J. Elec. Power Energy Syst.*, vol. 13, no. 5, pp. 268–276, 1991.
- [23] S. Guo and F. Salam, "The Number of (Equilibrium) Steady-State Solutions of Models of Power Systems," *IEEE Trans. Circuits Syst. I, Fundam. Theory Appl.*, vol. 41, no. 9, pp. 584–600, Sept. 1994.
- [24] V. Venikov, V. Stroeve, V. Idelchick, and V. Tarasov, "Estimation of Electrical Power System Steady-State Stability in Load Flow Calculations," *IEEE Trans. Power App. Syst.*, vol. 94, no. 3, pp. 1034–1041, May 1975.
- [25] Y. Tamura, H. Mori, and S. Iwamoto, "Relationship Between Voltage Instability and Multiple Load Flow Solutions in Electric Power Systems," *IEEE Trans. Power App. Syst.*, vol. PAS-102, no. 5, pp. 1115–1125, May 1983.
- [26] M. Ribbens-Pavella and F. Evans, "Direct Methods for Studying Dynamics of Large-Scale Electric Power Systems-A Survey," *Automatica*, vol. 21, no. 1, pp. 1–21, 1985.
- [27] H.-D. Chiang, F. Wu, and P. Varaiya, "Foundations of Direct Methods for Power System Transient Stability Analysis," *IEEE Trans. Circuits Syst.*, vol. 34, no. 2, pp. 160–173, Feb. 1987.
- [28] T. Overbye and C. DeMarco, "Improved Techniques for Power System Voltage Stability Assessment using Energy Methods," *IEEE Trans. Power Syst.*, vol. 6, no. 4, pp. 1446–1452, Nov. 1991.
- [29] W. Bukhsh, A. Grothey, K. McKinnon, and P. Trodden, "Local Solutions of the Optimal Power Flow Problem," vol. 28, no. 4, pp. 4780–4788, 2013.
- [30] D. Molzahn and I. Hiskens, "Moment-Based Relaxation of the Optimal Power Flow Problem," *18th Power Syst. Comput. Conf. (PSCC)*, 18-22 Aug. 2014.
- [31] A. Korsak, "On the Question of Uniqueness of Stable Load-Flow Solutions," *IEEE Trans. Power App. Syst.*, no. 3, pp. 1093–1100, 1972.
- [32] H. Nguyen and K. Turitsyn, "Appearance of Multiple Stable Load Flow Solutions under Power Flow Reversal Conditions," in *IEEE PES General Meeting*, July 2014.
- [33] —, "Voltage Multistability and Pulse Emergency Control for Distribution System With Power Flow Reversal," *IEEE Trans. Smart Grid*, no. 99, pp. 1–1, 2015.
- [34] T. Overbye and R. Klump, "Effective Calculation of Power System Low-Voltage Solutions," *IEEE Trans. Power Syst.*, vol. 11, no. 1, pp. 75–82, Feb. 1996.
- [35] R. Klump and T. Overbye, "A New Method for Finding Low-Voltage Power Flow Solutions," in *IEEE PES Summer Meeting*, 2000.
- [36] B. Lesieutre, D. Molzahn, A. Borden, and C. DeMarco, "Examining the Limits of the Application of Semidefinite Programming to Power Flow Problems," in *49th Annu. Allerton Conf. Commun., Control, Comput.*, Sept. 2011, pp. 1492–1499.
- [37] R. Guedes, L. Alberto, and N. Bretas, "Power System Low-Voltage Solutions Using an Auxiliary Gradient System for Voltage Collapse Purposes," *IEEE Trans. Power Syst.*, vol. 20, no. 3, pp. 1528–1537, Aug. 2005.
- [38] Y. Feng, "Solving for the Low-Voltage/Large-Angle Power-Flow Solutions by Using the Holomorphic Embedding Method," dissertation, Arizona State Univ., Aug. 2015, <http://repository.asu.edu/attachments/158002/content/Feng.asu.0010E.15211.pdf>.
- [39] W. Ma and S. Thorp, "An Efficient Algorithm to Locate All the Load Flow Solutions," *IEEE Trans. Power Syst.*, vol. 8, no. 3, p. 1077, 1993.
- [40] H. Chen, "Cascaded Stalling of Induction Motors in Fault-Induced Delayed Voltage Recovery (FIDVR)," *MS Thesis, Univ. Wisconsin-Madison, ECE Depart.*, 2011. [Online]. Available: <http://minds.wisconsin.edu/handle/1793/53749>
- [41] D. Molzahn, B. Lesieutre, and H. Chen, "Counterexample to a Continuation-Based Algorithm for Finding All Power Flow Solutions," *IEEE Trans. Power Syst.*, vol. 28, no. 1, pp. 564–565, 2013.
- [42] C.-W. Liu, C.-S. Chang, J.-A. Jiang, and G.-H. Yeh, "Toward a CPFLOW-based Algorithm to Compute All the Type-1 Load-Flow Solutions in Electric Power Systems," *IEEE Trans. Circuits Syst. I, Reg. Papers*, vol. 52, no. 3, pp. 625–630, Mar. 2005.
- [43] B. Lesieutre and D. Wu, "An Efficient Method to Locate All the Load Flow Solutions – Revisited," in *53rd Annu. Allerton Conf. Commun., Control, Comput.*, Sept. 29 - Oct. 2 2015.
- [44] D. Mehta, H. Nguyen, and K. Turitsyn, "Numerical Polynomial Homotopy Continuation Method to Locate All The Power Flow Solutions," *arXiv:1408.2732*, 2014.
- [45] S. Chandra, D. Mehta, and A. Chakraborty, "Exploring the Impact of Wind Penetration on Power System Equilibrium using a Numerical Continuation Approach," in *American Control Conference (ACC)*, 2015, pp. 4339–4344.
- [46] —, "Equilibria analysis of power systems using a numerical homotopy method," in *IEEE PES General Meeting*, July 26-30, 2015, pp. 1–5.
- [47] D. Mehta, N. S. Daleo, F. Dörfler, and J. D. Hauenstein, "Algebraic Geometrization of the Kuramoto Model: Equilibria and Stability Analysis," *Chaos*, vol. 25, no. 5, 2015.
- [48] J. Marecek, T. McCoy, and M. Mevissen, "Power Flow as an Algebraic System," *arXiv:1412.8054*, 2014.
- [49] D. Molzahn, D. Mehta, and M. Niemerg, "Toward Topologically Based Upper Bounds on the Number of Power Flow Solutions," *American Control Conf. (ACC)*, July 2016.
- [50] T. Chen and D. Mehta, "On the Network Topology Dependent Solution Count of the Algebraic Load Flow Equations," *arXiv:1512.04987*, Dec. 2015.
- [51] P. Dreesen and B. De Moor, "Polynomial Optimization Problems are Eigenvalue Problems," in *Model-Based Control: Bridging Rigorous Theory and Advanced Technology*, P. Hof, C. Scherer, and P. Heuberger, Eds. Springer US, 2009, pp. 49–68.
- [52] H. Mori and A. Yuihara, "Calculation of Multiple Power Flow Solutions with the Krawczyk Method," in *IEEE Int. Symp. Circuits Syst. (ISCAS)*, May 30 - June 2, 1999.
- [53] J.-B. Lasserre, *Moments, Positive Polynomials and Their Applications*. Imperial College Press, 2010, vol. 1.
- [54] J. Glover, M. Sarma, and T. Overbye, *Power System Analysis and Design*. Cengage Learning, 2011.
- [55] A. J. Sommese, J. Verschelde, and C. W. Wampler, "Introduction to Numerical Algebraic Geometry," in *Algorithms and Computation in Mathematics, Solving Polynomial Equations: Foundations, Algorithms, and Applications*, A. Dickenstein and I. Emiris, Eds. Springer-Verlag, 2005, vol. 14, pp. 339–392.
- [56] T. Y. Li, "Solving Polynomial Systems by the Homotopy Continuation Method," *Handbook of Numerical Analysis*, vol. XI, pp. 209–304, 2003.
- [57] A. J. Sommese and C. W. Wampler, *The Numerical Solution of Systems of Polynomials Arising in Engineering and Science*. World Scientific Publishing Company, 2005.
- [58] J. A. Acebrón, L. L. Bonilla, C. J. P. Vicente, F. Ritort, and R. Spigler, "The Kuramoto Model: A Simple Paradigm for Synchronization Phenomena," *Rev. Modern Phys.*, vol. 77, no. 1, p. 137, 2005.
- [59] F. Dörfler and F. Bullo, "On the critical coupling for kuramoto oscillators," *SIAM J. Appl. Dynam. Syst.*, vol. 10, no. 3, pp. 1070–1099, 2011.

- [60] E. L. Allgower and K. Georg, *Introduction to Numerical Continuation Methods*. SIAM, 2003, vol. 45.
- [61] D. N. Bernshtein, "The Number of Roots of a System of Equations," *Funct. Anal. Appl.*, vol. 9, no. 3, pp. 183–185, 1975.
- [62] A. G. Kushnirenko, "A Newton Polyhedron and the Number of Solutions of a System of k Equations in k Unknowns," *Usp. Math. Nauk*, vol. 30, pp. 266–267, 1975.
- [63] A. G. Khovanskii, "Newton Polyhedra and the Genus of Complete Intersections," *Funct. Anal. Appl.*, vol. 12, no. 1, pp. 38–46, 1978.
- [64] S. Guo and F. Salam, "Determining the Solutions of the Load Flow of Power Systems: Theoretical Results and Computer Implementation," in *IEEE 29th Ann. Conf. Decis. Contr. (CDC)*, Dec. 1990, pp. 1561–1566.
- [65] D. Cox, J. Little, and D. O'shea, *Ideals, Varieties, and Algorithms*. Springer, 1992, vol. 3.
- [66] D. Cifuentes and P. Parrilo, "Exploiting Chordal Structure in Polynomial Ideals: A Gröbner Bases Approach," *arXiv:1411.1745*, Nov. 2014.
- [67] J. Lavaei and S. Low, "Zero Duality Gap in Optimal Power Flow Problem," *IEEE Trans. Power Syst.*, vol. 27, no. 1, pp. 92–107, Feb. 2012.
- [68] R. Jabr, "Exploiting Sparsity in SDP Relaxations of the OPF Problem," vol. 27, no. 2, pp. 1138–1139, May 2012.
- [69] D. Molzahn, J. Holzer, B. Lesieutre, and C. DeMarco, "Implementation of a Large-Scale Optimal Power Flow Solver Based on Semidefinite Programming," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 3987–3998, Nov. 2013.
- [70] S. Low, "Convex Relaxation of Optimal Power Flow: Parts I & II," *IEEE Trans. Control Network Syst.*, vol. 1, no. 1, pp. 15–27, Mar. 2014.
- [71] E. Dall'Anese, H. Zhu, and G. Giannakis, "Distributed Optimal Power Flow for Smart Microgrids," *IEEE Trans. Smart Grid*, vol. 4, no. 3, pp. 1464–1475, Sept. 2013.
- [72] M. Andersen, A. Hansson, and L. Vandenberghe, "Reduced-Complexity Semidefinite Relaxations of Optimal Power Flow Problems," *IEEE Trans. Power Syst.*, vol. 29, no. 4, pp. 1855–1863, 2014.
- [73] C. Coffrin, H. Hijazi, and P. Van Hentenryck, "The QC Relaxation: Theoretical and Computational Results on Optimal Power Flow," To appear in *IEEE Trans. Power Syst.*
- [74] B. Kocuk, S. Dey, and A. Sun, "Strong SOCP Relaxations of the Optimal Power Flow Problem," To appear in *Oper. Res.*
- [75] R. Jabr, "Optimization of AC Transmission System Planning," *IEEE Trans. Power Syst.*, vol. 28, no. 3, pp. 2779–2787, Aug. 2013.
- [76] J. Taylor and F. Hover, "Conic AC Transmission System Planning," *IEEE Trans. Power Syst.*, vol. 28, no. 2, pp. 952–959, May 2013.
- [77] B. Zhang, A. Lam, A. Dominguez-Garcia, and D. Tse, "An Optimal and Distributed Method for Voltage Regulation in Power Distribution Systems," *IEEE Trans. Power Syst.*, vol. 30, no. 4, pp. 1714–1726, July 2015.
- [78] H. Zhu and G. Giannakis, "Power System Nonlinear State Estimation using Distributed Semidefinite Programming," *IEEE J. Sel. Topics Signal Process.*, vol. 8, no. 6, pp. 1039–1050, 2014.
- [79] C. Jozs, J. Maeght, P. Panciatici, and J. Gilbert, "Application of the Moment-SOS Approach to Global Optimization of the OPF Problem," *IEEE Trans. Power Syst.*, vol. 30, no. 1, pp. 463–470, Jan. 2015.
- [80] B. Ghaddar, J. Marecek, and M. Mevissen, "Optimal Power Flow as a Polynomial Optimization Problem," *IEEE Trans. Power Syst.*, vol. 31, no. 1, pp. 539–546, Jan. 2016.
- [81] D. Molzahn and I. Hiskens, "Sparsity-Exploiting Moment-Based Relaxations of the Optimal Power Flow Problem," *IEEE Trans. Power Syst.*, vol. 30, no. 6, pp. 3168–3180, Nov. 2015.
- [82] D. Molzahn, C. Jozs, I. Hiskens, and P. Panciatici, "Solution of Optimal Power Flow Problems using Moment Relaxations Augmented with Objective Function Penalization," *IEEE 54th Ann. Conf. Decis. Control (CDC)*, Dec. 2015.
- [83] C. Jozs and D. Molzahn, "Moment/Sums-of-Squares Hierarchy for Complex Polynomial Optimization," *Preprint: arXiv:1508.02068*, 2015.
- [84] D. Molzahn and I. Hiskens, "Mixed SDP/SOCP Moment Relaxations of the Optimal Power Flow Problem," in *IEEE Eindhoven PowerTech*, June 2015.
- [85] C. Jozs and D. Henrion, "Strong Duality in Lasserre's Hierarchy for Polynomial Optimization," *Springer, Optimiz. Letters*, 2015.
- [86] D. Molzahn and I. Hiskens, "Convex Relaxations of Optimal Power Flow Problems: An Illustrative Example," To appear in *IEEE Transactions on Circuits and Systems I: Regular Papers, Special Issue*, 2016.
- [87] H. Waki, S. Kim, M. Kojima, and M. Muramatsu, "Sums of Squares and Semidefinite Program Relaxations for Polynomial Optimization Problems with Structured Sparsity," *SIAM J. Optimiz.*, vol. 17, no. 1, pp. 218–242, 2006.
- [88] R. Gron, C. Johnson, E. Sá, and H. Wolkowicz, "Positive Definite Completions of Partial Hermitian Matrices," *Linear Algebra Appl.*, vol. 58, pp. 109–124, 1984.
- [89] D. Molzahn, C. Jozs, I. Hiskens, and P. Panciatici, "Computational Analysis of Sparsity-Exploiting Moment Relaxations of the OPF Problem," *19th Power Syst. Comput. Conf. (PSCC)*, June 20–24, 2016.
- [90] S. Boyd and L. Vandenberghe, *Convex Optimization*. Cambridge University Press, 2009.